

ELECTRO INDUSTRIES - FIELD SERVICE BULLETIN

Bulletin Number 1081 Date December 31, 2003

Product Name HeatChoice Plenum Heater, EH Series (EM-EU***C* or EM-ED***C*)

Effected Product Model Numbers:

	<u>ARL</u>	<u>Production Date</u>
EH-U**	2281	01-09-04
EH-D**	2281	01-09-04

FIELD INFORMATION

Blower may continue to operate after completion of heat call (electric elements turn off).


To our knowledge this condition only applies to some "power robbing" electronic thermostats such as Honeywell T8400C.

- After the above production date, modification to control board solves problem.

Field suggestions, **when** this may occur:

1. Mechanical thermostat.
2. Battery operated thermostat.
3. Thermostat with its own common wire.
4. Add isolation relay between thermostat and "W" terminal.

Approval



Date

1-12-04