

ELECTRO INDUSTRIES - FIELD SERVICE BULLETIN

Bulletin Number 1084

Date June 10, 2004

Product Name TS Boiler, EB-WA Series

Effected Product Model Numbers:

	<u>CSA Serial #</u>	<u>Production Date</u>
EB-WA Series	0563 - 0567	02-15-04 through 6-10-04

FIELD INFORMATION

At the beginning of the TS boiler release there was some question on whether the EB-WA, without outdoor sensing, was a required product option and whether or not it is even saleable because in essence it is very close to EB-S Series without the modulating triac. This model series and family was fully documented and went through full product certification, **but** some of the field documentation lagged behind.

You may have purchased an EB-WA-** model and found the installation manual and the front panel decal having slight misrepresented information. If this is the case, attached is the correct installation manual with the correct decal for the front panel. Also the table below helps illustrate the difference between the two model series.

EB-WO VERSUS EB-WA COMPARISON

The only difference is the outdoor sensor capability and programming associated with outdoor sensing outlet temperature ramping or preset value. Both model series use plug-in chip Version 6.2*, but specifies a 4-digit code for this temperature sensing programming.

Model Series	Outdoor Sensor (OT)	6.2* Code	Front Panel Decal	Install Manual
EB-WO	Required, connected	EBWO	UAI839	BI502
EB-WA	Not required	EBWA	UAI843	BI506

Approval



Date

6-10-04